

To: Egan, Robert[egan.robert@epa.gov]
Cc: Ruth, Scott[sruth@bristol-companies.com]; DePont, Lynn[DePont.Lynn@epa.gov]
From: Sharp-Dahl, Julie
Sent: Wed 12/10/2014 6:00:42 PM
Subject: TO 1019 Tower Standard analytical results
[10288974_frc.pdf](#)
[11-13-14 field sheets.pdf](#)
[sampling data sheet_Kirsten collected.pdf](#)

PLEASE NOTE THAT EPA AND CONTRACTORS ARE RECEIVING THIS EMAIL.

Hi Bob,

Attached are the tap water analytical results and field forms from the Tower Standard sampling event. I did a quick review of the data and it is usable as presented in the lab report. The results are reported to the MDL.

The only analyte detected above lab MDLs was lead. Only one tap water sample had a lead result that exceeded the screening levels presented in Table 2 of the *Private Well Sampling Plan*. The sample with the elevated lead result was collected from the second home sampled on November 13 (14284 Hwy 70 W). The lead result for this sample exceeded all screening criteria including Federal MCLs and had a reported concentration of 118 µg/L.

Please contact me if you have any questions.

Julie Sharp-Dahl
Senior Project Manager
Bristol Environmental Remediation Services, LLC
111 W. 16th Avenue, Third Floor
Anchorage, AK 99501-5109
Phone : (907) 743-9394
FAX : (907) 563-6713
jsharp-dahl@bristol-companies.com
<http://www.bristol-companies.com/>

CONFIDENTIAL NOTICE: This document is for the sole purpose of the intended recipient(s) and may contain confidential and privileged information. Any unauthorized review, use, disclosure, or distribution is prohibited. If you are not the intended recipient, please contact the sender and destroy all copies of the original document.

--